



## SCHEDULE TO PRODUCT CERTIFICATION LICENCE NO: 2671

### LICENCE DETAILS

**Scheme:** Product Certification

**Licensee:** KLC

**Address:** Corner Middle Road and Kennedy Street, Kaingaroa Village  
Waikato



---

### CONFORMANCE REQUIREMENTS

**Standard:** AS/NZS 1328.1:1998 Glued laminated structural timber

**Quality System:** Product Certification Quality System Requirements (QSR)

---

### CERTIFIED MODEL OR TYPE

**Species:** Pinus Radiata

**Design Strength:** 25MPa – GL12

**Service Class:** 1, 2 and 3

Service Class 3 has been approved through initial type testing.

Delamination test facility for ongoing production must be in place before compliance claim can be made for Service Class 3.

Note: if JAS method is used, this must be disclosed to purchasers specifying product compliant to AS/NZS 1328.1:1998.

**Adhesives:**

Adhesives shall be chosen to suit the end use of the product and be in accordance with clause 2.3.